



VENTILATION CALCULATION

- TO MAINTAIN ROOM AIR TEMPERATURE
- TO REDUCE THE HUMIDITY

$$\text{AIR FLOW REQUIREMENT} = \frac{\text{HEAT REMOVED (BTU)}}{1.08 \times \text{TEMPERATURE CHANGE (°F)}}$$

cfm

(CUBIC FEET PER MINUTE)



THE AIR FLOW RATE CAN BE PROVIDED BY ONE LARGER (OR) SEVERAL SMALLER COOLING UNITS. DEPENDING ON POSSIBLE ZONE WITHIN THE BUILDING.

pb A 4 000 sq ft RETAIL STORE NEAR TULSON, ARIZONA HAS BEEN CALCULATED TO HAVE SENSIBLE HEAT GAIN OF 100,000 BTU AT SUMMER DESIGN CONDITIONS (105 DB, 66 WB) FOR THIS LOCATION) CALCULATE HEAT REMOVED AND AIR FLOW RATE IN DOOR TO REDUCE 7°F TEMPERATURE.

$$\begin{aligned}\text{AIR FLOW RATE} &= \frac{\text{HEAT REMOVED (BTU)}}{1.08 \times \text{TEMPERATURE DIFFERENCE}} \\ (\text{CFM}) &= \frac{100,000}{1.08 \times 7} \\ &= 13227 \text{ CFM}\end{aligned}$$

PROPORTION OF AIR VOLUME FOR EACH PART OF BUILDING

$$\begin{array}{l} \text{AIR VOLUME FOR} \\ \text{PARTICULAR PART} \\ \text{OF BUILDING} \end{array} = \frac{\text{TOTAL AIR VOLUME}}{\text{TOTAL FLOOR AREA}} \times \frac{\text{FLOOR AREA OF PARTICULAR PART}}{\text{TOTAL FLOOR AREA}}$$

Pb THE WHOLE HOUSE NEEDS 13227 CFM
AIR FOR TOTAL FLOOR AREA 4000 SQ. FT.
CALCULATE THE AIR REQUIREMENT FOR EACH
PART OF THE HOME. ASSUME 66% OF
AIR IS APPLIED.

ALSO SKETCH THE OVERVIEW OF
AIR DUCTS.



$$\text{FAMILY ROOM} = \frac{60}{4000} \times 13227 \times 0.66 = 131 \text{ CFM}$$

$$\text{LIVING ROOM} = \frac{55}{4000} \times 13227 \times 0.66 = 120 \text{ CFM}$$

$$\text{BED ROOM 1} = \frac{44}{4000} \times 13227 \times 0.66 = 96 \text{ CFM}$$

$$\text{BED ROOM 2} = \frac{50}{4000} \times 13227 \times 0.66 = 110 \text{ CFM}$$

$$\text{Bed Room 3} = \frac{44}{4000} \times 13227 \times 0.66 = 96 \text{ CFM}$$

$$\text{DINING ROOM} = \frac{52}{4000} \times 13227 \times 0.66 = 113 \text{ CFM}$$

$$\text{KITCHEN} = \frac{72}{4000} \times 13227 \times 0.66 = 157 \text{ CFM}$$

$$\text{ENTRY} = \frac{25}{4000} \times 13227 \times 0.66 = 54.5 \text{ CFM}$$

$$\begin{aligned} \text{MAIN DUCT CAPACITY} &= 131 + 120 + 96 + 110 + 96 + 113 + 157 + 54.5 \\ &= 877.5 \text{ CFM} \end{aligned}$$

$$\text{Bed Room 3} = \frac{44}{4000} \times 13227 \times 0.66 = 96 \text{ CFM}$$

$$\text{DINING ROOM} = \frac{52}{4000} \times 13227 \times 0.66 = 113 \text{ CFM}$$

$$\text{KITCHEN} = \frac{72}{4000} \times 13227 \times 0.66 = 157 \text{ CFM}$$

$$\text{ENTRY} = \frac{25}{4000} \times 13227 \times 0.66 = 54.5 \text{ CFM}$$

$$\begin{aligned} \text{MAIN DUCT CAPACITY} &= 131 + 120 + 96 + 110 + 96 + 113 + 157 + 54.5 \\ &= 877.5 \text{ CFM} \end{aligned}$$

AVERAGE HEAT LOSS
PER MONTH

$$= \sum U A (T_i - T_a) \times N \times 0.0864$$

T_i = AVERAGE INTERNAL TEMPERATURE

T_a = AVERAGE MONTHLY AIR TEMPERATURE

N = NO. OF DAYS IN MONTH

TOTAL MONTHLY
HEAT LOSS DUE
TO VENTILATION
+
CONDUCTION

$$= \left[\sum U A \times 0.0864 + A C \times V \times 0.0286 \right] \times N$$

$A C$ = AIR CHANGE PER HOUR

V = VOLUME OF BUILDING